

STUDY TITLE

Assessment of Antibacterial Finishes on Textile Materials - AATCC Test Method 100

TEST ARTICLE NAME

GRAY MATTER WITH SILVER PRO

TEST ARTICLE IDENTIFICATION

RAE 120 AND 210

TEST ARTICLE PHYSICAL DESCRIPTION

BEC TECH GRAY MATTER WITH SILVER PRO AT A RATE = 120 AND ONE AT 210

TEST ARTICLE RECEIVED

October 15, 2014

SPONSOR

Ed Softsky
Quality Filters, Inc.
23351 Grissom Drive
Robertsdale, AL

PURPOSE

The purpose of this study is to evaluate the degree of antibacterial activity on the textile materials following a quantitative procedure.

RESULTS

Sample ID	Results (CFU/sample)					
	Zero Contact Time CFU / Specimen		24 hour Contact Time CFU / Specimen		Percent Reduction (%)	
	<i>S. aureus</i>	<i>K. pneumoniae</i>	<i>S. aureus</i>	<i>K. pneumoniae</i>	<i>S. aureus</i>	<i>K. pneumoniae</i>
RATE 120	2.40 x 10 ⁵	1.07 x 10 ⁵	< 1.00 x 10 ²	< 1.00 x 10 ²	> 99.96	> 99.91
RATE 210	2.50 x 10 ⁵	1.22 x 10 ⁵	< 1.00 x 10 ²	< 1.00 x 10 ²	> 99.96	> 99.92
	<i>A. brasiliensis</i>		<i>A. brasiliensis</i>		<i>A. brasiliensis</i>	
RATE 120	1.75 x 10 ⁵		3.50 x 10 ⁴		80.00	
RATE 210	1.65 x 10 ⁵		3.90 x 10 ⁴		76.36	

CFU = Colony Forming Units

The following formulas were used to calculate percent reduction.

% Reduction = B-A/B x 100

B = Number of bacteria recovered from inoculated test sample at 0 contact time.

A = Number of bacteria recovered from inoculated test sample in the jar incubated over desired contact period.

PROCEDURE

Specified layers of sample were inoculated evenly with the challenge organism. After inoculation, samples were incubated at specified temperature for 24 hours. Immediately after inoculation, zero contact time samples were neutralized with appropriate neutralizer. Serial dilutions were prepared and plated in duplicate using appropriate media. 24 hour samples were processed similarly.

All plates were incubated at 37 ± 2°C for 24-48 hours. The number of bacteria per specimen was reported and the percent reduction of bacteria was calculated.

TEST INFORMATION

Date Testing Initiated: 10-20-14 Date Testing Terminated: 10-27-14

Test Organism: *Staphylococcus aureus* Source No. 6538
 Klebsiella pneumoniae Source No. 4352
 Aspergillus brasiliensis Source No. 16404

Sample Size: 1 layer of 1 7/8" in diameter

Number of Layers: One (1)

Pre-treatment: Triton X

Neutralizer: Lethen Broth

Neutralizer Volume: 100 mL

Target Inoculum Level per sample: (1-2) x 10⁵ CFU

Inoculum Volume: 1.0 mL

Inoculum Population: *S. aureus* = 2.45 x 10⁵ CFU/mL
 K. pneumoniae = 1.37 x 10⁵ CFU/mL
 A. brasiliensis = 1.75 x 10⁵ CFU/mL

Incubation Temperature: 35-39°C / 27-29°C

COMMENT


Organisms were derived from an ATCC® organism, or an organism determined to be equivalent. ATCC is a registered trademark of American Type Culture Collection.

REFERENCE

The American Association of Textile Chemists and Colorists (AATCC) 100, Antibacterial Finishes on Textile Materials: Assessment of (2012).



APPROVAL Robert D. Hughes, BS Date 10-30-14
 Laboratory Operations Manager, Sterility Assurance

Results apply only to the test article tested. Any extrapolation of these data to other articles is the sponsor's responsibility. All procedures were conducted in conformance with good manufacturing practices, certified to ISO 13485:2003.

 <p>Blue Heaven Technologies</p> <p>2820 S. English Station Road - Louisville, KY 40299 Tel: (502) 357-0132 Fax (502) 287-8379</p>	<p>Date: 29-Apr-20 TEST NO. 20-235-1</p> <p style="text-align: center;">ASHRAE Standard 52.2-2017 TEST REPORT</p> <p style="text-align: center;">Initial Efficiency / Resistance</p>
--	---

Filter Description

<p>Manufacturer Filter Model Part Number Generic Filter Type Nominal Dimensions (H x W x D) Pocket / Pleat Quantity Media Type Est. Gross Media Area Adhesive Type</p>	<p>All Filters Inc Silver Micron N/A Pleated 24" x 24" x 1" 32 Pleats Synthetic 9.39Ft² N/A</p>
--	--



Test Conditions

Loading Dust Type	NA	Test Air Temp (degrees F.)	75
Barometric Pressure (In. Hg.)	29.02	Relative Humidity (%)	45

Test Results



Airflow Rate (CFM)	1180
Nominal Face Velocity (fpm)	295
Initial Resistance (in WG)	0.24
E1 (%) Initial Efficiency 0.30 - 1.0 um	28
E2 (%) Initial Efficiency 1.0 - 3.0 um	68
E3 (%) Initial Efficiency 3.0 - 10.0 um	87
Estimated * Minimum Efficiency Reporting Value (MERV) * If initial data is minimum	MERV 11 @ 1180 CFM

Comments Tested For: SilverMicron Technology

Test Performed by: CR Approved By:  Page 1 of 3

Important Note: Please be advised that the ASHRAE committee SSPC 52.2. In March 2016, has published "addendum e" relative to the 52.2-2012 test protocol. This addendum restricts the use of the acronym "MERV" as only applicable to a test report that has been completed using the "entire procedure prescribed by the standard". This report is a modified version of the procedure and therefore, subject to that ruling. In the best interest of our customers, Blue Heaven Technologies has elected to delay this action until further assessment can be made at committee level. Where applicable, the qualified use of the term "MERV" will continue to be part of our reported data.

Test No. 20-235-1
Date: 29-Apr-20



Test No. 20-235-1
 Date: 29-Apr-20

Data - Initial Resistance

Airflow (CFM)	Resistance (In WG)
0	0.00
295	0.04
590	0.10
885	0.16
1180	0.24
1475	0.33

Data - Particle Removal Efficiency

Particle Size Range (um)	Geometric Mean Diam (um)	Initial Particle Removal Efficiency (%)
0.30 - 0.40	0.35	15.2
0.40 - 0.55	0.47	22.6
0.55 - 0.70	0.62	30.9
0.70 - 1.00	0.84	41.4
1.00 - 1.30	1.14	54.8
1.30 - 1.60	1.44	63.5
1.60 - 2.20	1.88	72.3
2.20 - 3.00	2.57	81.6
3.00 - 4.00	3.46	86.7
4.00 - 5.50	4.69	87.7
5.50 - 7.00	6.20	86.9
7.00 - 10.00	8.37	85.2